

Appendix A

**Midland Waterworks Master Plan Update
Preliminary Servicing Strategies Technical
Memo (AECOM, March 18, 2019)**

To:
Andy Campbell, Town of Midland
Andre Pepin, Town of Midland

Project name:
Town of Midland Waterworks Master Plan
Update

CC:
Benny Wan, AECOM
Andrea Potter, AECOM
Randy Provencal, AECOM
Mukesh Choudhary, AECOM

Project ref:
60545937

From:
Semyon Chaymann

Date:
March 18, 2019

Memorandum

Subject: **Midland Waterworks Master Plan Update – Preliminary Servicing Strategies**

Introduction

AECOM Canada Inc. (AECOM) was retained as a consultant to update the Town of Midland Waterworks Master Plan. The previous Town of Midland Waterworks Master Plan was complete in 2013 and projected the waterworks requirements to 2031. The current update is using the estimated population growth to 2041 to determine the required infrastructure upgrades and capital works to meet the level of service that allows for a healthy and prosperous development in the Town of Midland. This Technical Memorandum summarizes the progress of the project, which includes:

- Estimation of future population in 5 year increments in each pressure zone;
- Evaluation of the storage, pump capacity, and well production capacity; and
- Selection of water servicing strategies.

Anticipated Population Growth

Estimated Population Growth in the Town of Midland

The table below illustrates the population forecasts and employment projections for the Town of Midland for the next 20 years. Note that the population projection for 2036 and 2041 are estimates only and have not been allocated by the County of Simcoe.

Table 1: Population and Employment Forecasts for the Town of Midland

Town of Midland	2006	2031	2036	2041
Population Forecasts	16,900	22,500	24,663	26,881
Employment Projections	12,000	13,800	15,127	16,487

Estimating Population Growth in Phases

A significant effort has been undertaken to estimate the population growth within the Town limits. The population forecasts and employment projections were made for the entire Town of Midland. In order to properly evaluate the Town of Midland water distribution system for existing and future conditions, the population projections must be distributed by pressure zones. Future growth information was gathered from the Town of Midland Planning Department. Existing and planned development information (Appendix C) and land use information (Appendix B) was used to create theoretical parcels of land where growth is expected (Figure 3). The type of growth (employment vs. residential) is defined by the existing land use information. For parcels where employment or residential information is not defined, an assumed split of 75% residential and 25% employment was assumed based on area of the parcel. The overall anticipated employment and residential growth was distributed by parcels using both land use information and the weighted ratio of residential vs. employment split calculated for the parcel with no land use information. The future population projections for growth areas is summarized in Table 2. The parcel ID number in Figure 3 are referenced in column 1 of Table 2. Parcels outside of the existing pressure zones were assigned to the closest existing pressure zone. No population growth was estimated for the existing built out areas of the Town. The results of the total population growth estimation are presented in Figure 1 and Figure 2.

Demand Calculation Assumptions

The following table lists assumption that were made to calculate the water demand requirements for the Town of Midland in this Waterworks Master Plan Update.

Description	Assumption
Per Capita Water Consumption for Existing Scenario (based on consumption records)	Residential – 200 lpcd Employment – 164 lpcd
Per Capita Water Consumption for Future Scenario (based on previous Water Master Plan estimates)	Residential – 246 lpcd Employment – 200 lpcd
Occupancy Rates (based on previous planning experience and previous Master Planning studies)	Low Density – 3.5 ppu Medium Density – 2.5 ppu High Density – 1.7 ppu Unknown – 2.2 ppu

Figure 1: Total Equivalent Population Growth by Pressure Zone




Figure 2: Total Estimated Population Growth for the Town of Midland




Figure 3: Town of Midland – Future Growth Areas




Table 2: Future Population Projections for Growth Areas

ID	Pressure Zone	Land Use*	Growth Area Type	Population									
				2021 - Res	2021 - Emp	2026 - Res	2026 - Emp	2031 - Res	2031 - Emp	2036 - Res	2036 - Emp	2041 - Res	2041 - Emp
1	Sunnyside	Residential	Draft Plans	-	-	322	-	-	-	-	-	-	-
2	East	Residential		928	-	-	-	-	-	-	-	-	-
3	East	Open Space		928	-	-	-	-	-	-	-	-	-
4	East	Open Space		928	-	-	-	-	-	-	-	-	-
5	East	Residential		928	-	-	-	-	-	-	-	-	-
6	East	Residential		-	-	444	-	-	-	-	-	-	-
7	Sunnyside	Residential		945	-	-	-	-	-	-	-	-	-
1	East	Open Space	Urban Uses	-	-	-	-	-	-	-	-	-	-
2	Sunnyside	Residential		-	-	-	-	30	-	307	-	315	-
3	East	Restricted Rural		-	41	-	41	29	41	302	105	309	108
4	East	Restricted Rural		-	8	-	8	5	8	56	19	57	20
5	East	Residential		-	-	-	-	1	-	7	-	7	-
6	West	Restricted Rural + Employment		-	114	-	114	82	114	835	291	856	298
7	West	Restricted Rural + Employment		-	54	-	54	39	54	397	138	407	142
8	East	Employment		-	39	-	39	-	39	-	98	-	100
9	East	Employment		-	49	-	49	-	49	-	124	-	127
10	East	Employment		-	42	-	42	-	42	-	107	-	110
11	East	Employment		-	23	-	23	-	23	-	60	-	61
12	East	Employment		-	7	-	7	-	7	-	17	-	17
13	East	Employment		-	2	-	2	-	2	-	6	-	6
14	East	Employment		-	109	-	109	19	109	199	277	204	284
15	West	Employment		-	33	-	33	6	33	61	85	62	87
Total Population				4,658	522	766	522	211	522	2,163	1,327	2,218	1,360

* Source: Town Of Midland - Official Plan Amendment No.1 - Schedule A

Table 3: Town of Midland - Existing and Future Estimated Population

	2016 (Existing)	2018	2021	2026	2031	2036	2041
Residential Population	16,864	18,727	21,522	22,289	22,500	24,663	26,881
Employment Population	12,233	12,442	12,755	13,278	13,800	15,127	16,487
Total Population	29,097	31,169	34,278	35,566	36,300	39,790	43,368

Storage, Pump Capacity, and Well Production Capacity Evaluation

The storage, pump capacity, and well production capacity evaluation is based on the estimated population growth numbers identified in the previous section of this Technical Memorandum. The Average Day Demand (ADD), Maximum Day Demand (MDD), and Peak Hour Demand (PHD) conditions were determined using the population projections and demand calculation assumptions.

Storage Capacity Requirement Evaluation

The storage capacity evaluation is based on the Ontario Ministry of Environment (MOE) storage requirement calculations. The detailed storage capacity calculations are attached in Table 4 and Table 5.

West Zone

The West pressure zone has two water storage facilities – Mountainview Tank (4.43ML) and Montreal Strandpipe (2.88ML). The calculated storage requirement in 2041 is 4.00 ML. This shows that the West pressure zone has a storage surplus of 3.32 ML.

East Zone (including Sunnyside and Lescout)

The East pressure zone has three water storage facilities – Dominion Standpipe (0.713ML), Everton Tank (5.80ML) and Hanly Tank (0.95ML). Sunnyside and Lescout pressure zones are direct pressure zones without floating storage therefore the storage requirement for these zones needs to be accounted for in the East Zone storage requirement calculations. The calculated storage requirement in 2041 for the East Zone, including Sunnyside and Lescout, is 10.37ML. This indicates that the East pressure zone has a storage deficiency of 4.55ML.

Storage Capacity Improvement Options

To improve storage capacity, a new water storage facility in the East pressure zone is required to provide sufficient fire, equalization, and emergency storage in the future.

Pump Capacity Requirement Evaluation

The pump capacity review calculations are attached in Table 4 and Table 5. The required firm pump capacity depends on whether there is adequate floating storage in the zone, does the floating storage cover fire storage requirement under the MOE fire considerations calculations, and does the floating storage cover equalization storage requirement under the same MOE required storage calculations?

East Zone

The East pressure zone has Wells 7A/7B (9.15MLD firm pump capacity), Flume Wellfield (6.55MLD firm pump capacity), and Well 15 (1.31MLD firm pump capacity) in operation for the total firm capacity of 17.02MLD. The required firm pump capacity for 2041 scenario in the East pressure zone is 15.45 MLD. Therefore the existing pump capacity is adequate to meet the future pump capacity requirements.

West Zone

The West pressure zone has Well 9 (1.96MLD firm pump capacity) and Dominion Pump Station (3.00MLD firm pump capacity), which transfers the required volume of water from the East pressure zone. The required firm pumping capacity for 2041 scenario is 4.62 MLD. Therefore, the existing pump capacity is adequate to meet the future pump capacity requirements.

Lescout Zone

The Lescout pressure zone has Hanly Booster Pump Station (0.82MLD firm pump capacity) and, according to the previous Waterworks Master Plan, Well 15 (1.31MLD firm pump capacity) can pump water into the zone. The required firm pumping capacity for 2041 scenario is 7.43MLD. This value is large because there is not floating storage in this direct pressure zone. Therefore, the pumping capacity in the Lescout pressure zone is inadequate to meet the future conditions.

Sunnyside Zone

Similar to the Lescout pressure zone, the Sunnyside pressure zone is a direct pressure zone and does not have a floating storage. The existing Everton Booster Pump Station (1.37MLD firm pump capacity) is inadequate to meet the required firm pump capacity of 6.03 MLD.

Pump Capacity Improvement Options

To improve pump capacity, fire pumps at Hanly BPS and Everton BPS are required to provide sufficient fire flow supply.

Well Production Requirement Evaluation

The well production capacity evaluation is based on the existing source capacity. For a conservative groundwater supply, it is assumed that the largest production capacity well is out of service for the zone in which it exists.

East Zone (including Sunnyside and Lescout)

Similar to the storage capacity evaluation, the East pressure zone combines the source water requirements for Sunnyside and Lescout because wells located in the East pressure zone provide water to the direct pressure zones. The supply capacity requirement is based on the Maximum Day Demand conditions. The East pressure zone has groundwater supply from Wells 7A/7B (9.15MLD), Flume clearwell (7.13MLD), and Well 15 (1.31MLD). With the largest well (7A) out the supply capacity is 12.67MLD. The required supply capacity for 2041 for the East pressure zone, including Sunnyside and Lescout, is 11.41MLD.

West Zone

The West pressure zone has Well 9 (1.96MLD) as the only groundwater well that is supplying water directly into the zone. The West pressure zone supply requirement under the MDD conditions in 2041 is 4.62 MLD. The supply deficiency is usually offset by the transfer of flow from the East pressure zone. The transfer requirement is calculated by taking the West zone supply requirement (MDD) and subtracting the Well 9 supply capacity. In 2041 the transfer requirement is calculated to be 2.66 MLD, while the East pressure zone surplus is only 1.26 MLD. Therefore, there is overall groundwater supply deficiency of 1.40 MLD by 2041.

Well Production Improvement Options

To improve overall groundwater supply security, additional well supply is required. It is important to note that because West pressure zone relies on the transfer of flow from the East pressure zone, securing groundwater well supply in the West pressure zone would add to the water supply security in that zone.

Table 4: Storage, Pump Capacity, and Well Production Capacity Calculations

Zone East															
Storage Info															
Volume (ML) Floating?															
	Volume (ML)		Floating?												
Dominion	0.713		yes												
Sunnyside	5.80		Yes												
Hanly	0.95		Yes												
Scenario	Population		Demand (ML/d)			MOECC Fire Considerations			Storage (ML)			Storage Requirement (ML)	Available Storage (ML)	Storage Surplus/Deficit	Adequate Storage?
	RES	EMP	ADD	MDD	PHD	Sugg. FF (L/s)	Duration (hrs)	Fire	Equalization	Emergency					
2018	13,511	8,556	4.14	7.71	11.57	250	4	3.60	1.93	1.38	6.91	7.46	0.55	Yes	
2021	16,306	8,716	4.86	9.04	13.56	250	4	3.60	2.26	1.47	7.33	7.46	0.14	Yes	
2026	17,072	8,987	5.10	9.49	14.24	250	4	3.60	2.37	1.49	7.47	7.46	0.00	No	
2031	17,092	9,258	5.16	9.60	14.40	250	4	3.60	2.40	1.50	7.50	7.46	-0.04	No	
2036	17,291	9,946	5.35	9.95	14.92	318	5	5.72	2.49	2.05	10.26	7.46	-2.80	No	
2041	17,495	10,651	5.54	10.30	15.45	318	5	5.72	2.58	2.07	10.37	7.46	-2.91	No	

Zone West															
Storage Info															
Volume (ML) Floating?															
	Volume (ML)		Floating?												
Mountainview	4.43		Yes												
Montreal	2.881		no												
Scenario	Population		Demand (ML/d)			MOECC Fire Considerations			Storage (ML)			Storage Requirement (ML)	Available Storage (ML)	Storage Surplus/Deficit	Adequate Storage?
	RES	EMP	ADD	MDD	PHD	Sugg. FF (L/s)	Duration (hrs)	Fire	Equalization	Emergency					
2018	3,847	2,840	1.2513	2.314	3.47	159	3	1.72	0.58	0.57	2.87	7.31	4.44	Yes	
2021	3,847	3,056	1.2772	2.361	3.54	159	3	1.72	0.59	0.58	2.88	7.31	4.43	Yes	
2026	3,847	3,308	1.3275	2.454	3.68	159	3	1.72	0.61	0.58	2.91	7.31	4.40	Yes	
2031	4,008	3,559	1.4175	2.621	3.93	159	3	1.72	0.66	0.59	2.97	7.31	4.35	Yes	
2036	5,659	4,198	1.9517	3.609	5.41	159	3	1.72	0.90	0.65	3.27	7.31	4.04	Yes	
2041	7,351	4,852	2.4995	4.621	6.93	189	3	2.04	1.16	0.80	4.00	7.31	3.32	Yes	

Zone Lescout															
Storage Info															
Volume (ML) Floating?															
	Volume (ML)		Floating?												
Scenario	Population		Demand (ML/d)			MOECC Fire Considerations			Storage (ML)			Storage Requirement (ML)	Available Storage (ML)	Storage Surplus/Deficit	Adequate Storage?
	RES	EMP	ADD	MDD	PHD	Sugg. FF (L/s)	Duration (hrs)	Fire	Equalization	Emergency					
2018	1,060	713	0.3294	0.609	0.91	79	2	0.57	0.15	0.18	0.90	0.00	-0.90	No	
2021	1,060	713	0.3294	0.609	0.91	79	2	0.57	0.15	0.18	0.90	0.00	-0.90	No	
2026	1,060	713	0.3294	0.609	0.91	79	2	0.57	0.15	0.18	0.90	0.00	-0.90	No	
2031	1,060	713	0.3294	0.609	0.91	79	2	0.57	0.15	0.18	0.90	0.00	-0.90	No	
2036	1,060	713	0.3294	0.609	0.91	79	2	0.57	0.15	0.18	0.90	0.00	-0.90	No	
2041	1,060	713	0.3294	0.609	0.91	79	2	0.57	0.15	0.18	0.90	0.00	-0.90	No	

Zone Sunnyside															
Storage Info															
Volume (ML) Floating?															
	Volume (ML)		Floating?												
Scenario	Population		Demand (ML/d)			MOECC Fire Considerations			Storage (ML)			Storage Requirement (ML)	Available Storage (ML)	Storage Surplus/Deficit	Adequate Storage?
	RES	EMP	ADD	MDD	PHD	Sugg. FF (L/s)	Duration (hrs)	Fire	Equalization	Emergency					
2018	309	247	0.1025	0.189	0.28	38	2	0.27	0.05	0.08	0.40	0.00	-0.40	No	
2021	309	271	0.1073	0.198	0.30	38	2	0.27	0.05	0.08	0.40	0.00	-0.40	No	
2026	309	271	0.1073	0.198	0.30	38	2	0.27	0.05	0.08	0.40	0.00	-0.40	No	
2031	340	271	0.1149	0.212	0.32	38	2	0.27	0.05	0.08	0.41	0.00	-0.41	No	
2036	654	271	0.1921	0.355	0.53	38	2	0.27	0.09	0.09	0.45	0.00	-0.45	No	
2041	975	271	0.2713	0.502	0.75	64	2	0.46	0.13	0.15	0.73	0.00	-0.73	No	

Zone East					
Pump Info					
Total Floating Stor		Station Name		Existing Firm Pumping Capacity (ML/d)	
7.46		Well 7A		4.92	
		Well 7B		4.23	
		Flume PS Firm Capacity		6.55	
		Well 15		1.31	
				15.71	
Adequate Floating Storage?	Floating Storage Covers Fire?	Floating Storage Covers Equalization?	Design Flow Condition	Required Firm Pumping Capacity (ML/d)	Firm Capacity - No. of Largest Pumps Offline
Yes	Yes	Yes	MDD	7.71	1
Yes	Yes	Yes	MDD	9.04	1
No	Yes	Yes	Lesser of PHD and MDD+FF	14.24	2
No	Yes	Yes	Lesser of PHD and MDD+FF	14.40	2
No	Yes	Yes	Lesser of PHD and MDD+FF	14.92	2
No	Yes	Yes	Lesser of PHD and MDD+FF	15.45	2

Zone West					
Pump Info					
Total Floating Stor		Station Name		Existing Firm Pumping Capacity (ML/d)	
4.43		Well 9 Supply (l/s)		1.96	
		Dominion PS		3.00	
				4.96	
Adequate Floating Storage?	Floating Storage Covers Fire?	Floating Storage Covers Equalization?	Design Flow Condition	Required Firm Pumping Capacity (ML/d)	Firm Capacity - No. of Largest Pumps Offline
Yes	Yes	Yes	MDD	2.31	1
Yes	Yes	Yes	MDD	2.36	1
Yes	Yes	Yes	MDD	2.45	1
Yes	Yes	Yes	MDD	2.62	1
Yes	Yes	Yes	MDD	3.61	1
Yes	Yes	Yes	MDD	4.62	1

Zone Lescout					
Pump Info					
Total Floating Stor		Station Name		Existing Firm Pumping Capacity (ML/d)	
0.00		Hanly BPS		0.82	
		Well 15		1.31	
				2.13	
Adequate Floating Storage?	Floating Storage Covers Fire?	Floating Storage Covers Equalization?	Design Flow Condition	Required Firm Pumping Capacity (ML/d)	Firm Capacity - No. of Largest Pumps Offline
No	No	No	Larger of PHD and MDD+FF	7.43	2
No	No	No	Larger of PHD and MDD+FF	7.43	2
No	No	No	Larger of PHD and MDD+FF	7.43	2
No	No	No	Larger of PHD and MDD+FF	7.43	2
No	No	No	Larger of PHD and MDD+FF	7.43	2
No	No	No	Larger of PHD and MDD+FF	7.43	2

Zone Sunnyside					
Pump Info					
Total Floating Stor		Station Name		Existing Firm Pumping Capacity (ML/d)	
0.00		Sunnyside BPS		1.37	
				1.37	
Adequate Floating Storage?	Floating Storage Covers Fire?	Floating Storage Covers Equalization?	Design Flow Condition	Required Firm Pumping Capacity (ML/d)	Firm Capacity - No. of Largest Pumps Offline
No	No	No	Larger of PHD and MDD+FF	3.47	2
No	No	No	Larger of PHD and MDD+FF	3.48	2
No	No	No	Larger of PHD and MDD+FF	3.48	2
No	No	No	Larger of PHD and MDD+FF	3.50	2
No	No	No	Larger of PHD and MDD+FF	3.64	2
No	No	No	Larger of PHD and MDD+FF	6.03	2

Table 5: Storage, Pump Capacity, and Well Production Capacity Calculations – Continued


Zone East		Station Name		Existing Source Capacity (ML/d)		
Source Info		Well 7A		4.92		
Flume Clearwell (MLD) 7.13		Well 7B		4.23		
Well 6	1.64	Flume Clearwell		7.13		
Well 11	1.96	Well 15		1.31		
Well 12	0.66			* 12.67		
Well 14	0.98			*Largest Well Out		
Well 16	1.31					
Well 17	1.23					
Zone East	Required Supply Capacity (ML/d)	Zone Sunnyside	Required Supply Capacity (ML/d)	Zone Lescout	Required Supply Capacity (ML/d)	Total
MDD	7.71	MDD	0.19	MDD	0.61	8.51
MDD	8.61	MDD	0.63	MDD	0.61	9.85
MDD	8.92	MDD	0.78	MDD	0.61	10.30
MDD	9.02	MDD	0.79	MDD	0.61	10.42
MDD	9.37	MDD	0.93	MDD	0.61	10.91
MDD	9.72	MDD	1.08	MDD	0.61	11.41
Zone West		Station Name		Existing Firm Pumping Capacity (ML/d)		
Source Info		Well 9		1.96		
				1.96		
Zone West	Required Supply Capacity (ML/d)	Transfer Requirement from Zone West (MLD)	Zone East Surplus Capacity (MLD)	Overall Supply Capacity Surplus (MLD)		
MDD	2.31	0.35	4.16	3.81		
MDD	2.36	0.40	2.82	2.42		
MDD	2.45	0.49	2.37	1.88		
MDD	2.62	0.66	2.25	1.59		
MDD	3.61	1.64	1.76	0.11		
MDD	4.62	2.66	1.26	-1.40		

Selected Water Servicing Strategies for Consideration

As part of the Waterworks Master Plan Update, AECOM is evaluating a number of servicing alternatives and projects that could improve on the issues identified within the existing water distribution network (Figure 4) as well as storage, pump capacity, and well production supply capacity shortages identified through requirement evaluation in the previous section of this Memorandum.

Based on the evaluation, the servicing strategies and encompassing alternatives can be summarized as:

1. Improve storage capacity in the East Pressure Zone
 - a. Alternative 1A – New Storage Tank at Wellfield 7A/7B



- b. Alternative 1B – New Storage Tank at Hwy. 12 and King St.



- c. Alternative 1C – Replace Dominion Standpipe with New Storage Tank
 - d. Alternative 1D – Replace Hanly ET with New Storage Tank
 - e. Alternative 1F – New Storage Tank in Sunnyside Pressure Zone
 - f. Alternative 1D – New Storage Tank in Lescout Pressure Zone
 - g. Alternative 1E – New Storage Tank in New Pressure Zone (south of Little Lake)
2. Secure additional groundwater supply
- a. Alternative 2A – Commission Sundowner Well with new water treatment

- b. Alternative 2B – Place Well 1A back in service
 - c. Alternative 2C – Undertake a study to determine a new groundwater well location
3. Improve fire flow supply to direct pressure zones
- a. Alternative 3A/3B – Increase firm pump capacity and install fire pump at Everton BPS and Hanly BPS
 - b. Alternative 3C – Dedicate Well 15 to Lescout Pressure Zone and install fire pump at Hanly BPS
4. Provide sustainable water service to future development
- a. Alternative 4A – Connect area south of Little Lake to West Pressure Zone through new Highway 93 watermain
 - b. Alternative 4B – Create a New Pressure Zone south of Little Lake with Booster Pump Station
 - c. Alternative 4C – Twin the existing Harbourview Drive watermain

The identified strategies are evaluated based on technical criteria which encompasses operational complexity, energy use, system optimization, constructability, capital requirements, and the ability to mitigate existing key servicing issues. Details of the technical evaluation criteria are described in Table 6.


Table 6: Technical Evaluation Criteria

Technical Criteria	Description
Operational Complexity	Changes in the system operation may require additional SOPs and staff training. Reduced operational complexity is a benefit as it becomes easier to manage and operate the water system
Energy Use	Changes in the operation may increase or decrease overall energy use and energy required to meet the adequate service levels
System Optimization	Ability to maximize/optimize existing infrastructure or avoid upgrades
Capital Requirements	Amount of new infrastructure required
Key Issue Resolution	Ability to mitigate known issues

Next Steps

The selected servicing strategies will be evaluated for technical feasibility using the outlined technical evaluation criteria as well as the hydraulic model. The hydraulic model analysis is used to identify linear infrastructure limitations for the selected servicing strategies. As a result of this technical evaluation preferred strategies will be identified. The preferred strategies will be presented to the public in Public Information Centre #2 for comment.

Figure 4: Existing issues and solutions map – Town of Midland Waterworks



Preferred Servicing Strategy

Based on the evaluation of the servicing alternatives, the following is a preferred servicing strategy:

- Alternative 1B – New Storage Tank (5.26ML) at Highway 12 and King Street intersection
- Alternative 2A – Commission Sundowner Well in the West Pressure Zone
- Alternative 3A/3B – Increase firm pump capacity and install fire pump at Everton BPS and Hanly BPS
- Alternative 4B - Create a New Pressure Zone south of Little Lake with Booster Pump Station

The preferred servicing strategy addresses key issues identified at the inception of the Waterworks Master Plan Update:

- a) Low pressure experienced around the area north of Highway 12 and west of King Street can be mitigated by creating a new pressure zone south of Little Lake.
- b) Dominion Standpipe is aging and requires rehabilitation. With commissioning of a new storage tank with enough storage capacity, Dominion Standpipe can be demolished.
- c) Montreal Tank requires coating at an estimated cost of \$150,000 and, according to the Operations staff, is difficult to operate. Based on the population growth in the West Pressure zone, there is sufficient storage capacity to abandon the Montreal Tank.
- d) Lescout Pressure zone experiences inadequate fire flow supply. This can be mitigated through upgrade of the existing Hanly BPS with a fire pump.
- e) Well 9 is the only groundwater well supplying the West Pressure Zone and therefore the West Pressure Zone relies on Dominion Booster Pump Station to transfer flow from the East Pressure Zone. Commissioning Sundowner Well with new water treatment would increase groundwater supply in the West Pressure Zone and reduce the reliance on Dominion BPS for transfer of flow from the East Pressure Zone.
- f) Well 15 needs structural repairs. Through the analysis, it was identified that Well 15 is important in providing groundwater supply to the system and has the ability to increase firm supply capacity to Lescout Pressure Zone.
- g) Well 12 is in poor condition and it is recommended that it is abandoned.
- h) Well 1A, located in the East Pressure Zone, could increase overall groundwater supply capacity. However, the West Pressure Zone would still rely on Dominion BPS to transfer the flow.

Appendix A – Maps of Servicing Strategies and Alternatives



Town of Midland Waterworks Master Plan Update 2019


Preliminary Servicing Strategies and Alternatives



AECOM

Existing Issues and Solutions Map

Town of Midland Waterworks Master Plan Update 2019




Legend		Water Mains (by Diameter)	
	Pump House		19 - 100 mm
	Well House		101 - 200 mm
	Booster Pump Station		201 - 300 mm
	Water Treatment System		301 - 400 mm
	Water Storage		
	Points of Interest		Town of Midland
	Wildlife Centre		Water Mains (by Diameter)
	Municipal Wells (by Type)		Freeway
	De-Commissioned		Highway
	Observation		Major Road
	Production		Collector Road
	Sampling Well		Local Road
			Watercourse
			Waterbody
			Municipal Boundary



ISSUES AND SOLUTIONS

- A Issue - Redundancy**
Single feed watermain (300 mm) along Harbourview Dr. supplies to the Everton and Portage Park Pressure Zones
Solutions
1)Twin the existing watermain to improve the system redundancy, or
2)Recommission the wells (#22 and #23) in the Portage Park Pressure Zone, for emergency use
- B Issue - Sundowner Well Water Quality**
Solutions
Treatment process will be required.
- C Issue - Pressure**
Low pressure experienced around the area north of Highway 12 and west of King St.
Solutions
1)Provide new storage tank near Well 7A and 7B to higher water level; control water level for Russell Tower, or
2)Install a new local Booster Pump Station
- D Issue - Aging Infrastructure**
Dominion Standpipe is more than 100 years old and requires rehabilitation. Parts of the Town have aging watermains that contribute to water quality and odour issues at times.
Solutions
1)Refurbish existing storage facility, or
2)Abandon (if not required), or
3)Demolish existing and install a new storage facility at another location, or
4)Demolish existing and install a new storage facility at the same location.
5)Identify possible pipe replacement and flushing program requirements.
- E Issue - Maintenance Cost and Operational Concerns**
Montreal Tank requires coating (estimated cost of \$150k) and is difficult to operate (i.e. requires pumping).
Solutions
1)Refurbish, or
2)Abandon (if not required)
- F Issue - Fire Flow Constraint**
Fire flow supply in Lescaut Pressure Zone not adequate
Solutions
Provide fire pump for Lescaut Pressure Zone
- G Issue - Capacity Constraint**
Well 9 capacity is not enough to meet the West Pressure Zone demand
Solutions
1)Place Sundowner well in service, or
2)Install a new tank near the Mountainview Standpipe with a new feedermain from Flume Pressure Zone
- H Issue - Well Life Expectancy**
Wells 7A and 7B are major supply source; more than 30 years old.
Solutions
1)Replace wells, or
2)Perform detailed Geotechnical works to control wells condition.
- I Issue - Well Physical Integrity**
Well 15 needs structural repairs (such as casing)
Solutions
1)Refurbish the well
2)Abandon (if not required)
- J Issue - Physical Integrity**
Well 12 in poor condition and beyond repair
Solutions
1)Install a new well, or
2)Abandon (if not required)
- K Issue - Well Not in Service**
Well 1A currently not in use
Solutions
1)Place the well in service to improve system's well supply capacity (if required), or
2)Abandon (if not required)
- L Issue - New Water Service Required for Future Development**
Solutions
Requires new infrastructure to provide sustainable water service to future development.



Datum: NAD 83 Zone 17
Source: AECOM, CLOCA, LIO, Town of Whitby

AECOM

This drawing has been prepared for the use of AECOM's client and may not be used, reproduced or relied upon by third parties, except as agreed by AECOM and its client, as required by law or for law by governmental reviewing agencies. AECOM accepts no responsibility, and denies any liability whatsoever, to any party that modifies this drawing without AECOM's express written consent.



Proposed Service Improvement Strategies

1. Improve Storage Capacity in the East Pressure Zone
2. Secure Additional Groundwater Supply Capacity
3. Improve Fire Flow Supply to Direct Pressure Zones
4. Provide Sustainable Water Service to Future Development




Improve Storage Capacity in the East Pressure Zone

Town of Midland Waterworks Master Plan Update 2019


Storage Capacity Improvement Alternative 1A

New 2.88ML Tank at Wellfield
7A/7B



Storage Capacity Improvement Alternative 1B


New 2.88ML Tank at Hwy 12 and King St.





Storage Capacity Improvement Alternative 1C

Replace Dominion Standpipe
with new 2.88ML tank



Dominion Standpipe

West Pressure Zone

Pressure Zone

Portage Park Pressure Zone

Reservoir / Flume Pressure Zone

Lescaut Pressure Zone


Legend

- ② Pump House
 - ⊙ Well House
 - ⊕ Booster Pump Station
 - ★ Water Treatment System
 - ⊙ Water Storage
 - ⊙ Points of Interest
 - Ⓜ Shrine / Museum
 - 🌿 Wildlife Centre
- | Water Mains (by Diameter) | |
|---------------------------|--------------------|
| 19 - 100 mm | Freeway |
| 101 - 200 mm | Highway |
| 201 - 300 mm | Major Road |
| 301 - 400 mm | Collector Road |
| | Local Road |
| | Watercourse |
| | Waterbody |
| | Municipal Boundary |
| | Town of Midland |



Storage Capacity Improvement Alternative 1D

Replace Hanly ET with new
2.88ML tank



Hanly ET

West Pressure Zone

Pressure Zone

Portage Park Pressure Zone

Reservoir / Flume Pressure Zone


Lescaut Pressure Zone

Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
Water Mains (by Diameter)	
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland



Storage Capacity Improvement Alternative 1E

New Tank in Sunnyside Zone



West Pressure Zone

Pressure Zone

Portage Park Pressure Zone

New 2.88ML Tank


Reservoir / Flume Pressure Zone

Lescaut Pressure Zone

- Legend**
- ⊕ Pump House
 - ⊙ Well House
 - ⊕ Booster Pump Station
 - ★ Water Treatment System
 - ⊙ Water Storage
 - ⊙ Points of Interest
 - ⊙ Shrine / Museum
 - ⊙ Wildlife Centre
- Water Mains (by Diameter)**
- 19 - 100 mm
 - 101 - 200 mm
 - 201 - 300 mm
 - 301 - 400 mm
- Freeway
 - Highway
 - Major Road
 - Collector Road
 - Local Road
 - Watercourse
 - Waterbody
 - Municipal Boundary
 - Town of Midland

Storage Capacity Improvement Alternative 1F

New Tank in Lescout Zone




New 2.88ML Tank

Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
Water Mains (by Diameter)	
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland



Storage Capacity Improvement Alternative 1G

New 2.88ML Tank in New
Pressure Zone



West
Pressure
Zone

Pressure
Zone

Portage Park
Pressure
Zone

Reservoir / Flume
Pressure
Zone

Lescaut
Pressure
Zone

New Pressure Zone

New Tank

Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
Water Mains (by Diameter)	
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland






AECOM

Secure Additional Groundwater Supply Capacity

Town of Midland Waterworks Master Plan Update 2019

Groundwater Supply Capacity Improvement Alternative 2A

Commission Sundowner Well with new
treatment



Sundowner Well

West Pressure Zone

Reservoir / Flume Pressure Zone

Lescaut Pressure Zone


Portage Park Pressure Zone

Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
Water Mains (by Diameter)	
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland



Groundwater Supply Capacity Improvement Alternative 2B

Place Well 1A back in service



Portage Park Pressure Zone


Well 1A

Reservoir / Flume Pressure Zone

West Pressure Zone

Lescaut Pressure Zone

Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
Water Mains (by Diameter)	
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland



West Pressure Zone

Pressure Zone

Portage Park Pressure Zone

Reservoir / Flume Pressure Zone

Lescaut Pressure Zone

Groundwater Supply Capacity Improvement Alternative 2C

Undertake a study to determine a new groundwater well location within town limits and connect it to the water distribution system

- Legend**
- ② Pump House
 - ⊕ Well House
 - ⊕ Booster Pump Station
 - ★ Water Treatment System
 - ⊕ Water Storage
 - ⊕ Points of Interest
 - ⊕ Shrine / Museum
 - ⊕ Wildlife Centre
- Water Mains (by Diameter)**
- 19 - 100 mm
 - 101 - 200 mm
 - 201 - 300 mm
 - 301 - 400 mm
- Freeway
 - Highway
 - Major Road
 - Collector Road
 - Local Road
 - Watercourse
 - Waterbody
 - Municipal Boundary
 - Town of Midland



AECOM


Improve Fire Flow Supply to Direct Pressure Zones

Town of Midland Waterworks Master Plan Update 2019



Pump Capacity Improvement Alternative 3A

Increase firm pump capacity at Hanly BPS and upgrade Hanly BPS with fire pump to increase fire flow supply to Lescout Pressure Zone



Legend

	Pump House		19 - 100 mm		Freeway
	Well House		101 - 200 mm		Highway
	Booster Pump Station		201 - 300 mm		Major Road
	Water Treatment System		301 - 400 mm		Collector Road
	Water Storage				Local Road
	Points of Interest		Watercourse		Waterbody
	Shrine / Museum		Municipal Boundary		Town of Midland
	Wildlife Centre				





Everton BPS

Everton Tank

Pressure Zone

MIDLAND POINT RD

Portage Park Pressure Zone

GOLF LINK RD

West Pressure Zone

VINDIN ST

Midland Harbour

Reservoir / Flume Pressure Zone

Mountainview Standpipe

Montreal Tank

Dominion Standpipe

HUGEL AVE

BAYSHORE DR

Lescaut Pressure Zone

BALM BEACH RD E

TOWN OF MIDLAND

Little Lake

Pump Capacity Improvement Alternative 3B

Upgrade Everton BPS with fire pump to increase fire flow supply to Sunnyside Pressure Zone

Harbourview Dr

King St

William St

Hanly Tower

GALLOWAY BLVD

BAYVIEW AVE


Legend

	Pump House		19 - 100 mm		Freeway
	Well House		101 - 200 mm		Highway
	Booster Pump Station		201 - 300 mm		Major Road
	Water Treatment System		301 - 400 mm		Collector Road
	Water Storage				Local Road
	Points of Interest				Watercourse
	Shrine / Museum		Waterbody		Municipal Boundary
	Wildlife Centre		Town of Midland		



Pump Capacity Improvement Alternative 3C

Dedicate Well 15 to Lescout and upgrade Hanly BPS with fire pump to increase fire flow supply to Lescout Pressure Zone



Well 15

Hanly BPS

Reservoir / Flume Pressure Zone

Lescout Pressure Zone

Portage Park Pressure Zone

Pressure Zone

- Legend**
- Pump House
 - Well House
 - Booster Pump Station
 - Water Treatment System
 - Water Storage
 - Points of Interest
 - Shrine / Museum
 - Wildlife Centre
- Water Mains (by Diameter)**
- 19 - 100 mm
 - 101 - 200 mm
 - 201 - 300 mm
 - 301 - 400 mm
- Freeway
 - Highway
 - Major Road
 - Collector Road
 - Local Road
 - Watercourse
 - Waterbody
 - Municipal Boundary
 - Town of Midland






Provide Sustainable Water Service to Future Development

Town of Midland Waterworks Master Plan Update 2019

Future Development Water Supply Alternative 4A

Connect areas south of Little Lake to West Zone through new watermain along Highway 93




Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
Water Mains (by Diameter)	
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland



Future Development Water Supply Alternative 4B

Create a new direct pressure zone south of Little Lake



Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
	Water Mains (by Diameter)
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland



Twin watermain

Pressure Zone


Portage Park Pressure Zone

West Pressure Zone

Reservoir / Flume Pressure Zone

Lescaut Pressure Zone

Future Development Water Supply Alternative 4C
Twin the existing Harbourview Dr watermain to improve redundancy of supply to Sunnyside



Legend	
	Pump House
	Well House
	Booster Pump Station
	Water Treatment System
	Water Storage
	Points of Interest
	Shrine / Museum
	Wildlife Centre
Water Mains (by Diameter)	
	19 - 100 mm
	101 - 200 mm
	201 - 300 mm
	301 - 400 mm
	Freeway
	Highway
	Major Road
	Collector Road
	Local Road
	Watercourse
	Waterbody
	Municipal Boundary
	Town of Midland

Appendix B - Official Plan Land Use Map

TOWN OF MIDLAND



OFFICIAL PLAN LAND USE SCHEDULE 'A'

TOWN OF PENETANGUISHENE

Waste Disposal Assessment Area 500 m

Limits of Former Landfill

SECONDARY PLAN
Subject to Section 3.6.6

EXCEPTION
Subject to Section 3.3.13.7

SPECIAL POLICIES
Subject to Section 3.3.7

GEORGIAN BAY

TOWNSHIP OF TINY

SPECIAL POLICIES
Subject to Section 3.3.13.5

LITTLE LAKE

SPECIAL POLICIES
Subject to Section 3.3.13.6








SPECIAL POLICIES
Subject to Section 3.3.7

AGGREGATE RESOURCES
Subject to Section 3.6.5

SECONDARY PLAN
Subject to Section 3.6.6

THIS IS SCHEDULE "A" TO
OFFICIAL PLAN AMENDMENT
No. 1 TO THE OFFICIAL PLAN
OF THE TOWN OF MIDLAND

Legend


-  Employment Areas
-  Downtown District
-  Residential District
-  Open Space District
-  Environmental Protection
-  Restricted Rural
-  Waterfront Mixed-Use

SPECIAL POLICIES
Subject to Section 3.1.6.1

AGGREGATE RESOURCES
Subject to Section 3.6.5


WYE MARSH

TOWNSHIP OF TAY







DRAWN BY: TOWN OF MIDLAND PLANNING DEPARTMENT
DATE: FEBRUARY 2004
OFFICE CONSOLIDATION: NOVEMBER 2017

Appendix C – Development Planning Information provided by Town of Midland



Legend

-  Draft_Plan
-  Corrected_Built_Boundary
-  Lands_for_urban_uses
-  Municipal_Boundary - Settlement Area